



केंद्रीय विद्यालय, दापोरिजो

KENDRIYA VIDYALAYA, DAPORIJO

शिक्षा मंत्रालय, भारत सरकार

Ministry of Education, Govt. of India

जिला-ऊपरी सुबानसिरी, अरुणाचल प्रदेश, पिन 791122

DIST.- UPPER SUBANSIRI ARUNACHAL PRADESH, PIN 791122

E mail:kvdaporijo2019@gmail.com; Website: <https://daporijo.kvs.ac.in>

U-DISE 12060604207 Tel. 03792-224488 KV Code 2406 Station code 877

फ42007 -.सं. /के/दापोरिजो .वि .2022-23/ 155

दिनांक:06.10.2022

प्रभारी अधिकारी/ The Officer –In- charge
फायर स्टेशन दापोरिजो/ Fire Station Daporijo
ऊपरी सुबानसिरी जिला/ Upper Subansiri District
अरुणाचल प्रदेश/ Arunachal Pradesh

Sub: Request for issuance of Fire Safety certificate –reg
Ref No-DRJ/PS-31/07-08 dated 7th June 2022

Sir,

As per the above said reference you have advised us to procure and install firefighting equipments. The direction has been initiated by this office and the same will be completed within 15 days.

As per the direction given in point No-4, I would like to bring to your kind notice that at present KV Daporijo is functioning at a temporary building provided by the District Administration, Upper Subansiri till the construction of Permanent building and any modification/construction in the temporary building is not permitted by KVS as per Rules.

Hence I request your good self to survey the school after 21st of this month and issue fire Safety Certificate as it is essential for completing the formalities of Affiliation process with CBSE.

With regards

o/c

भवदीय

3/13/22

(आशा कृष्णा नायर .पी)

प्रभारी प्राचार्या

हस्ताक्षर/Principal

केंद्रीय विद्यालय/Kendriya Vidyalaya
दापोरिजो/Daporijo



**GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE FIRE & EMERGENCY SERVICES
UPPER SUBANSIRI DISTRICT
DAPORIJO**

NO. DRJ/FS/31/07-08

Dated Daporijo the 07th June'2022

//NOTICE/INSPECTION REPORT//

To,

The Principal In-Charge
Kendriya Vidyalaya, Daporijo
Upper Subansiri District
Arunachal Pradesh

Sir, Madam,

Survey/Inspection of your School i.e. "KENDRIYA VIDYALAYA Daporijo have been officially inspected by undersigned on 06TH June 2022 and the following Fire Fighting Equipments are required to be installed which are vital for the Fire Safety and preventive measures.


1. Co2 Extinguisher 03 nos.
2. DCP Extinguisher 08 nos.
3. Water Tank Capacity 500 ltrs
4. Emergency Exit/Escapes route at Each Building

Above mentioned First Aid Fire fighting equipments and requirements should be installed and fulfilled within 01(one) month from the date of issue of this Notice.

Place: Daporijo

Date of Issue: 07/06/2022

Counter Sign:


26/06/22
Officer in Charge
Fire Station Daporijo
Upper Subansiri District.
(A-P)



केंद्रीय विद्यालय, दापोरिजो

KENDRIYA VIDYALAYA, DAPORIJO

शिक्षा मंत्रालय, भारत सरकार

Ministry of Education, Govt. of India.

जिला-ऊपरी सुबानसिरी, अरुणाचल प्रदेश, पिन 791122

DIST.- UPPER SUBANSIRI ARUNACHAL PRADESH, PIN 791122

E mail:kvdaporijo2019@gmail.com; Website: <https://daporijo.kvs.ac.in>

U-DISE 12060604207 Tel. 03792-224488 KV Code 2406 Station code 877

फ. सं. - 2406/के. वि. दापोरिजो/2022-23/49

Dated: 31-05-2022


To
The Office Incharge
Fire Department
Daporijo, Arunachal Pradesh

Subject: Request to provide duplicate Fire safety certificate regarding

As per the subject cited above, earlier we got fire safety certificate from your organization. While handling the files the issued copy was missed. Therefore we are requesting you to kindly provide a **Renewal duplicate copy of fire safety certificate**. This copy is essential for vidyalaya and regional office level.

Your cooperation is highly appreciated.

Thank you

Received on
01.06.2022.

01.06.2022.
→ 9085692264.

Yours faithfully



K Sainath

Principal I/c

हाथ्याय/Principal
केन्द्रीय विद्यालय/Kendriya Vidyalaya
दापोरिजो/Daporijo



GOVT. OF ARUNACHAL PRADESH
OFFICE OF THE FIRE AND EMERGENCY SERVICES
UPPER SUBANSIRI DISTRICT
DAPORIJO.

TO WHOM IT MAY CONCERN

This is to certify that the proposed site for "Kendriya Vidyalaya" at Daporijo, Upper Subansiri District, Arunachal Pradesh, an educational institution has been officially inspected by the undersigned on 20th June'2019 and found the building/ compound is suitable for its purpose.

Place :- DAPORIJO
Date: 20-06-2019

डाकरी नं। Dy No	640
डाक प्राप्ति की तिथि/ Date of receipt of	20/06/19.

A0
[Signature]
20/06/19

[Signature]
25/6/19
Officer-in-Charge
Fire Service, Daporijo
Upper Subansiri District

Officer in-Charge
Fire Station, Daporijo
(A.P.)